

PANEL "P"

*22,000 AMPS. RMS. SYM. I.C. EQUIPMENT RATING

	120/240	VOLTS	1 ϕ	3 WIRE	125 AMPS	MLO	FULLY RATED		
SERVES	A ϕ	B ϕ	TRIP	BKR	BKR	TRIP	A ϕ	B ϕ	SERVES
** FUEL PUMP			30	1		2	20		LIGHTS
			2	3		4	20		LIGHTS
** FUEL PUMP			30	5		6	20		EXISTING
			2	7		8	20		
** FUEL PUMP			30	9		10	20		
			2	11		12	20		
** FUEL DISPENSER			20	13		14	20		
** FUEL DISPENSER			20	15		16	20		
** FUEL DISPENSER			20	17		18	20		
** PUMP CONTRO BOX			20	19		20	20		
** TANK MONITORING			20	21		22	20		
** VOICE COMM SYS			20	23		24	20		
RECEPTACLES			20	25		26	20		SPARE
RECEPTACLES			20	27		28	20		
SPARE			20	29		30	20		
			20	31		32			
			20	33		34			
			20	35		36			
			20	37		38			
			20	39		40			
			20	41	TOTAL	42			
				A ϕ					
				B ϕ					
			TOTAL CONN. LOAD			KVA			

* VERIFY W/ELEC UTIL CO.

** SWITCH NEUTRAL, FIELD VERIFY SIZES AND EXACT REQUIREMENTS

NEW FUELING FACILITY FOR DESOTO PARISH
ROAD DEPARTMENT

ADDENDUM # 2

09/15/14

EDMONDS ENGINEERING SERVICES